INSTALLATION INSTRUCTIONS E-WR1L LED WRAP

e-conolight®



IMPORTANT SAFEGUARDS

When using electrical equipment, basic safety precautions should always be followed including the following:

READ AND FOLLOW ALL SAFETY INSTRUCTIONS

- DANGER- Risk of shock- Disconnect power before installation.
 DANGER Risque de choc Couper l'alimentation avant l'installation.
- 2. This luminaire must be installed in accordance with the NEC or your local electrical code. If you are not familiar with these codes and requirements, consult a qualified electrician. Ce produit doit être installé conformément à NEC ou votre code électrique local. Si vous n'êtes pas familier avec ces codes et ces exigences, veuillez contacter un électricien qualifié.
- 3. Min 60°C supply conductors and connectors.

 Les fils d'alimentation et les connecteurs 60°C min.


SAVE THESE INSTRUCTIONS FOR FUTURE REFERENCE

Notes:

 E-WR LED Wrap is designed for surface mount applications using the included hardware kit.

INSTALLATION

- Remove the cover plate of the luminaire by removing the (2) screws and set screws aside to reinstall later. See Figure 1.
- Loosen the (2) captive screws that hold the driver bracket in place. Once the screws are removed the driver will swing out. See Figure 2.
- Attach mounting bracket to the junction box using supplied hardware. See Figure 3.
- 4. Position luminaire over threaded rod. See Figure 3.
- When positioned secure the luminaire using mounting nut. Ensuring that the luminaire is flushed to the surface. See Figure 4.
- Make electrical connections with supplied wire nuts as following:
 - · Connect the Line to Black
 - Neutral to White
 - Ground to Green



- Document:
 LPN00241X0001A0
 Date
 2014-4-02

 Created By:
 TMT
 DCR#
 2014-068
 - Swing the driver back into the housing, ensuring not to pinch any leads. See Figure 5.
- 8. Re-secure driver to the mounting plate by tightening (2) screws that were loosened in Step 2.
- 9. Reinstall cover plate that was removed in Step 1.

FIGURE 1




FIGURE 2




FIGURE 3




FIGURE 4





FIGURE 5



FAX: 262.504.5409